



BID QUESTIONS #2

Fernandina Medical Office Building

Lime Street
Fernandina Beach, Florida

BID DATE: March 18, 2010 @ 2:00 p.m.

Auld & White Constructors, LLC
4168 Southpoint Parkway, Suite 101
Jacksonville, Florida 32216
Phone #: (904) 296-2555 Bid Fax # (904) 296-1896

TO: All Selected Subs/Vendors
FROM: Jodi Marson, Estimating Assistant

DATE: March 11, 2010

Please review the following information issued as Bid Set Questions/Answers #2 for the Fernandina Medical Office Building. Trades affected are noted for each.

Bid Set Question #5– (MASONRY, ROOF & STOREFRONT)

1. Regarding the stone on the exterior - price Environmental Stoneworks – Southern LedgeStone. Color selection has not been made yet.
2. 30# felt should be installed over the OSB under the metal roof, in lieu of the 15# felt indicated on the drawings. This is from the roof manufacturer's specs.
3. For bid purposes, terminate the rear downspouts to a standard concrete splash block.
4. Regarding the storefront windows- as noted on A7.1, please price single pane impact glazing. Thermal break system is not required.

