

## Melody P. DeGross

---

**From:** Melody P. DeGross  
**Sent:** Wednesday, July 21, 2010 7:13 AM  
**To:** Melody P. DeGross  
**Subject:** 2790 NFCU - River City Marketplace Branch Jacksonville, Florida - Pre-bid RFI #04

### PREBID RFI #04

---

**From:** Chris\_Hill@URSCorp.com [mailto:Chris\_Hill@URSCorp.com]  
**Sent:** Tuesday, July 20, 2010 3:10 PM  
**To:** Melody P. DeGross  
**Cc:** Scott D. McPeck; Charles\_Crowell@URSCorp.com  
**Subject:** Re: 2790 NFCU - River City Marketplace Branch Jacksonville, Florida - Pre-bid RFI #04

#### Responses to Prebid RFI #4:

1. Detail 5 on sheet C-08 indicates 8" of aggregate base course under the 8" of concrete pavement. Is this necessary? If so, what material should be used here (e.g. Limerock, Crushed Concrete, Coquina Shell, EZ-Base, Soil Cement, etc.)? Can we choose a material from a list of approved materials? Please advise.

**Response:** *Yes the aggregate base is required. Per Section 8 of the Geotechnical Report (as referenced by the detail), any material approved by FDOT for pavement sub-base may be used. It FDOT does not have specific recommendation(s) the Geotechnical Engineer recommends following ASTM D 2490 "Graded Aggregate Material for Bases or Subbases for Highways and Airports."*

2. Detail 6 on sheet C-08 indicates a 6" base course under the asphalt pavement. What material should be used here (e.g. Limerock, Crushed Concrete, Coquina Shell, EZ-Base, Soil Cement, etc.)? Can we choose a material from a list of approved materials? Please advise.

**Response:** *Per Section 8 of the Geotechnical Report (as referenced by the detail), any material approved by FDOT for pavement sub-base may be used. It FDOT does not have specific recommendation(s) the Geotechnical Engineer recommends following ASTM D 2490 "Graded Aggregate Material for Bases or Subbases for Highways and Airports."*

3. Can you please clarify what is considered a pavement marking and what is pavement striping so we can correctly price what is to be thermoplastic and what is to be paint?

**Response:** *All pavement markings are to be striped unless specifically noted on the plans as thermoplastic.*

Chris Hill, PE, CFM

URS - Atlanta  
1000 Abernathy Road N.E., Suite 900  
Atlanta, Georgia 30328  
Main: (678) 808-8800  
Direct: (678) 808-8862  
Mobile: (678) 458-7965  
Fax: (678) 808-8400  
E-mail: [Chris\\_Hill@URSCORP.com](mailto:Chris_Hill@URSCORP.com)

This e-mail and any attachments contain URS Corporation confidential information that may be proprietary or privileged. If you receive this message in error or are not the intended recipient, you should not retain, distribute, disclose or use any of this information and you should destroy the e-mail and any attachments or copies.