

**Melody P. DeGross**

---

**From:** kim [kim@greenhut.com]  
**Sent:** Friday, July 23, 2010 1:26 PM  
**To:** Scott D. McPeck  
**Cc:** Melody P. DeGross  
**Subject:** FW: NFCU River City Marketplace - RFI

RFI Question:

Please clarify the size and gauge of material to be used for the security mesh for the walls.

Thank you,

Kim

*Kim Aderholdt, LEED AP BDC  
Project Coordinator  
Greenhut Construction Company  
Ph: 850.433.5421  
Fx: 850.435.9826  
[www.greenhut.com](http://www.greenhut.com)*

Please refer to sheet AE001 spec section 09 23 00. The mesh shall be an Amico Security Mesh product "Maximum Security" with a mesh thickness of .120".

Scott McPeck 7/26/10